

# Preliminary Assessment Report

## Project 3029046, 312 N 104TH ST

---

**Assessment Completed:** 9/19/2017

**Project Description:** Application for Conditional Use permit to change use from non-conforming grandfathered workshop use (light manufacturing use) to marijuana growing and processing use (includes urban farm, food processing and light manufacturing uses) in a SF 5000 zone.

**Primary Applicant:** [Gabrielle Muller](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### SDCI Drainage Requirements

Matthew Bateman, (206) 615-1229, [Matthew.Bateman@Seattle.gov](mailto:Matthew.Bateman@Seattle.gov)

#### SDCI Land Use Requirements

Eddie Buker, (206) 386-1246, [gerald.buker@seattle.gov](mailto:gerald.buker@seattle.gov)

#### SDCI Preapplication Site Visit Requirements

Tsegaye Hailu, (206) 615-0840, [tsegaye.hailu@seattle.gov](mailto:tsegaye.hailu@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Rachel Huck, (206) 386-1108, [Rachel.Huck@seattle.gov](mailto:Rachel.Huck@seattle.gov)

#### Seattle Public Utilities Requirements

Jim Mahady, (206) 684-5950, [Jim.Mahady@seattle.gov](mailto:Jim.Mahady@seattle.gov)

#### Water Availability

SPU Staff, (206) 684-3333, [SPUWaterAvailability@Seattle.Gov](mailto:SPUWaterAvailability@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **SDCI Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

**\*\*The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.\*\***

#### **Existing Public Drainage Infrastructure**

Sanitary sewer main location: **N 104th St / N 105th St**

Sanitary sewer main size: **8" / 8"**

Other location: **N 105th St (far side in N 105th St)**

Other size: **12"**

#### **Drainage**

The storm drainage point of discharge (SMC 22.805.020) is located at: **On site (infiltration)** (Or Culvert in N 105th St)

#### **Wastewater**

The wastewater point of discharge (SMC 21.16.070.B) is located at **Public Sanitary Sewer**.

#### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: **Onsite Infiltration (if feasible)**.

### **SDCI Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

##### **N 104TH ST**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

##### **N 105TH ST**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### **Alley Requirements**

##### **ALLEY**

Based on the submitted documents, no alley improvements are required per SMC 23.53.030

#### **Land Use**

Based on the proposed use and location within a residential, multi-family, or commercial zone, an administrative conditional use permit may be required. See CAMs 211A and 211B for more details.

## Other Requirements

Based on the preliminary scope of the project, DPD recommends a presubmittal conference prior to submitting an application. Details for preparing and submitting a presubmittal conference request form can be found at our Web site ([http://www.seattle.gov/dpd/Publications/Forms/Building\\_Permit/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp)).

## Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the SDCI Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by SDCI within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

## ECA Mapping Unit and Type

Non-ECA

## Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

## Existing ROW Conditions

### N 104TH ST

Street conditions:

Asphalt paving

Curb conditions:

No curb adjacent to site

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

### N 105TH ST

Street conditions:

Concrete paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5 inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### ALLEY

Gravel surface

## Potential Impacts to Seattle Parks Property

No parks property in vicinity

## Tree Protection

Existing trees appear to be shown accurately on the site plan

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

## **Seattle City Light Requirements**

### **Notes to Applicant**

To ensure that the existing service at the site can provide for the improvements and change of use, please provide new electrical load information to City Light. Power for the new manufacturing must come from the existing electrical service to the site per SCL's "one site-one service" rule. If a new or revised electrical service is needed, the Electrical Service Representative for your area must be contacted several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. Your Electrical Service Representative is: Patty Breidenbach, 206-684-4795, [patty.breidenbach@seattle.gov](mailto:patty.breidenbach@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

### **Other Requirements**

- If three-phase power is needed, an extension of City Light's distribution system is required to provide sufficient power to the project site. Please contact your Electric Service Representative for further discussion.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

### **City planning context**

The following current and upcoming projects may affect the right-of-way adjacent to your project:

Project initiation, analysis, design and construction for prioritized localized drainage problems within Thornton Creek.

## **SPU Requirements**

### **Water Availability**

Your water availability assessment is in progress. If the assessment results in water system improvements, you will be required to follow SDOT's Street Improvement Permit Process (see [CAM 2211](#) and [CAM 2213](#)).

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

## **Other Requirements**

### **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).